

**Icicle Streambank Restoration RM-1.0
Bidder Questions and Clarifications**

Question	Response	Date
There is a log sizing discrepancy between the plans and the specs. Which indicate the correct lengths for piles?	The complete wood schedule shown in the special provisions provides the correct wood quantities and sizes for each structure type. *3/7/2022- Addendum No. 2 will be issued by COB and will include the updated plan set with the corrected log sizing's for each structure type to match that shown in the special provisions.	March 4 th , 2022
Can logs be staged onsite prior to construction?	Yes, landowner is willing to have logs staged on site prior to construction- this timing will be coordinated closely with the Contracting Agency and the landowner.	March 4 th , 2022
Is Builder's Risk Insurance required?	The insurance requirements outlined by the Contracting Agency for this project are outlined in section 1-07.18 of the Special Provisions.	March 4 th , 2022
Can a standard hydraulic vibratory hammer with a timber boot be used in the place of the side grip vibratory hammer?	The Contracting Agency and the Engineer are open to reviewing a change in piledriving equipment available for use upon request as long as the Contractor can confirm and outline how all design criteria and permit requirements will be met.	March 7 th , 2022
Do the fence posts require concrete/grout or is backfilling with the native material allowed?	Any new/ reinstallation of the fence will match whatever materials and installation methods are onsite. We have been told that the current fence posts are dug and backfilled.	March 8 th , 2022
Can we spoil any bulkbag fill onsite?	There <u>may be</u> locations in which limited amounts of bulkbag fill material could be incorporated onsite, however this would be a field fit decision and it would not account for all fill material.	March 10 th , 2022

Section 1-07.5 & .6 talks about a CSWGP but it is not listed as a permit that the county has acquired. Is one required and has/is the county acquiring and paying for it?	If a CSWGP is required, the County will acquire and pay all associated fees.	March 11 th , 2022
--	--	-------------------------------