Ozburn- Eagle Creek Culvert Replacement Project Bidder Questions and Clarifications		
Question	Response	Date
Can the temporary traffic bypass be installed upstream of the footbridge?	No; placing a bypass in this location would not allow enough room for excavation of the new structure.	3/31/23
Does the County need to approve the weight limit and specs of the temporary crossing? What are the temporary bridge specs?	See 8-05.3 of the Special Provisions.	3/31/23
Should the temporary traffic bypass be placed on ecology blocks or will there be excavation needed?	This is the determination of the Contractor. Means, methods and materials for installation of the Traffic Bypass shall be outlined in the affiliated submittal as outlined in sections 1-05.8 and 8-05 of the special provisions.	3/31/23
What will flows be in October?	There is no active flow measurement occurring for this site, however flows are typically between 1-2 cfs on average. There is a potential for higher rainfall in late October which would impact this estimate.	3/31/23
Where does ground-water need to go from the sump?	See final plans and section 8-01 of the special provisions. Clean water which meets all permit standards may be routed around the work area and pumped downstream as part of the bypass system. All sediment laden water must be handled accordingly.	3/31/23
Can logs and other materials in the staging area be moved?	Yes, all materials staged there unassociated with the project will be moved prior to construction.	3/31/23
What are the specs of the new guardrail?	WSDOT Standard Plan C-10. See sheet 6 of the final drawings.	3/31/23

Is there anything other than fill	The current landowner believes	3/31/23
around the existing culvert?	there may be relict footings	
	subsurface on either side of the	
	current culvert, but that is	
	unconfirmed. If present, the	
	approximate original size was ~	
	8"x3'x10'. The previous	
	landowner believes they were	
	removed as part of the	
	installation of the current	
	culvert.	
Getting a culvert by the current	We do not have a preferred	4/4/23
project deadline might be an	vendor/ supplier/	
issue. Do you have any	manufacturer. The project work	
recommendations or	window is established by the	
preferences on a culvert	permitters for the project	
supplier? If one cannot be	therefore shall remain the	
found this year, can the project	effective work window. The	
be extended or pushed to	goal is to construct the project	
2024?	within the referenced 2023	
	work-window.	