

September 2, 2020



**SNOW LAKES #1 TRAIL BRIDGE PROJECT  
CHELAN COUNTY NATURAL RESOURCE DEPARTMENT**

**ADDENDUM NO. 3**

To the Contractors, Subcontractors and Suppliers:

The following items contain additions, deletions, or modifications to the Plans and Specifications. This Addendum forms a part of the Contract Documents.

Bidders shall acknowledge receipt of this Addendum on their Bid Proposal Form.

1. Add the following requirements following paragraph 9-09.3(1) of the WSDOT Standard Specifications:

Glulam deck panels and solid sawn members shall meet the following minimum preservative retention requirements and AWPA Use Categories:

COMPONENT	MINIMUM TOTAL RETENTION pcf	MINIMUM COMPONENTS RETENTION		
		pcf		
		Propiconazole pcf	Tebuconazole pcf	Imidacloprid pcf
Solid Sawn Members	0.018	0.007	0.007	0.0007
Glulam Deck Panels	0.021	0.0081	0.0081	0.00081

COMPONENT	AWPA USE CATEGORY
Solid Sawn Members	UC3B
Glulam Deck Panels	UC4A

END OF ADDENDUM NO. 3

**Pete Cruickshank**  
**Chelan County Natural Resource Department**  
411 Washington St., Suite 201  
Wenatchee, WA 98801  
Phone: 509-667-6612  
Mobile 509-699-1754  
Email: [pete.cruickshank@co.chelan.wa.us](mailto:pete.cruickshank@co.chelan.wa.us)